

Parámetros de Calidad de Gas a introducir en los convertidores PTZ durante el Primer Semestre de 2018



Posición Position	PCS SCV kWh/m ³ (n)	PCI ICV kWh/m ³ (n)	Densidad relativa Density	N ₂ % mol	CO ₂ % mol	Variación PCS %
03A	11,779	10,615	0,6028	0,3398	0,2692	-1,2%
H1	10,996	9,888	0,5642	1,4088	0,0000	-1,4%
CC.SG.UF	11,800	10,635	0,6045	0,3835	0,2665	-1,3%
I013	11,775	10,610	0,6001	0,2741	0,1689	-1,3%
04B.1	11,779	10,615	0,6028	0,3398	0,2692	-1,2%
F06	11,448	10,308	0,5882	0,9256	0,1636	-1,2%
15.11	11,800	10,635	0,6045	0,3835	0,2665	-1,4%
15.11-01	11,800	10,635	0,6045	0,3835	0,2665	-1,4%
H00	11,551	10,402	0,5879	0,5806	0,0000	1,0%
N07EC	11,822	10,659	0,6198	1,2526	0,5632	1,0%
C3	11,813	10,648	0,6068	0,5343	0,2602	1,1%
A0	11,719	10,563	0,6106	0,8358	0,6345	1,1%
15.34.3	11,577	10,427	0,5905	0,5913	0,0693	1,2%
15.34.31	11,577	10,427	0,5905	0,5913	0,0693	1,2%
CC.CG.IB	11,577	10,427	0,5905	0,5913	0,0693	1,2%
O05.1.02	11,744	10,588	0,6202	1,3301	0,8175	1,2%
CC.CG.AE	11,740	10,582	0,6098	0,6879	0,6059	1,4%
D07.01	11,847	10,678	0,6059	0,4385	0,1479	1,7%
D07.03	11,873	10,701	0,6040	0,2957	0,0283	2,0%
D07.06	11,875	10,703	0,6038	0,2879	0,0184	2,0%
D0702-A	11,877	10,705	0,6038	0,2790	0,0124	2,0%
D07.08	11,877	10,705	0,6037	0,2767	0,0091	2,0%
D07.09	11,877	10,705	0,6037	0,2767	0,0091	2,0%
D07.10	11,877	10,705	0,6037	0,2767	0,0091	2,0%
D07.11	11,877	10,705	0,6037	0,2767	0,0091	2,0%
D07.12	11,877	10,705	0,6037	0,2767	0,0091	2,0%
D07.13	11,877	10,705	0,6037	0,2767	0,0091	2,0%
D07.14	11,877	10,705	0,6037	0,2767	0,0091	2,0%
F27.1	11,752	10,597	0,6277	1,3795	1,2236	N/A
K02.02-E	11,713	10,564	0,6348	2,1779	1,2733	N/A